



Department of  
Environmental  
Conservation

## Spill Incidents Database Search Details

---

### Spill Record

#### Administrative Information

**DEC Region:** 1

**Spill Number:** 0310194

#### Spill Date/Time

**Spill Date:** 12/02/2003    **Spill Time:** 09:22:00 AM

**Call Received Date:** 12/02/2003    **Call Received Time:** 09:22:00 AM

#### Location

**Spill Name:** SUB STATION

**Address:** 600 STEWART AVENUE

**City:** GARDEN CITY    **County:** Nassau

#### Spill Description

##### Material Spilled Amount Spilled Resource Affected

dielectric fluid            80 Gal.            Soil

**Cause:** Equipment Failure

**Source:** Commercial/Industrial

**Waterbody:**

#### Record Close

**Date Spill Closed:** 01/10/2005

"Date Spill Closed" means the date the spill case was closed by the case manager in the Department of Environmental Conservation (the Department). The spill case was closed because either; a) the records and data submitted indicate that the necessary cleanup and removal actions have been completed and no further remedial activities are necessary, or b) the case was closed for administrative reasons (e.g., multiple reports of a single spill consolidated into a single spill number). The Department however reserves the right to require additional remedial work in relation to the spill, if in the future it determines that further action is necessary.

If you have questions about this reported incident, please contact the [Regional Office](#) where the incident occurred.

[Return To Results](#)

[Refine This Search](#)